



MICHAEL BARLOW WELL DRILLING & SERVICE, INC.

522 Underwood Lane
(410) 838-6910

Bel Air, Maryland 21014
Fax (410) 838-3582

WELL YIELD REPORT

Date Test Completed:	October 25, 2021		
Well Depth:	200	feet	
Customer	Christine Lobos	Permit #	HA-18-0131
Road	Churchville Road	Subdivision	Oakwood Subdivision
City	Churchville	Section	
State	Maryland	Lot #	1

Time	Water Level feet	Time to Fill 1-gallon bucket seconds	G.P.M.
8:30 AM	14	4	15.00
8:45 AM	19	4	15.00
9:00 AM	19	4	15.00
9:15 AM	20	4	15.00
9:30 AM	20	4	15.00
9:45 AM	20	4	15.00
10:00 AM	20	4	15.00
10:15 AM	20	4	15.00
10:30 AM	20	4	15.00
10:45 AM	20	4	15.00
11:00 AM	20	4	15.00
11:15 AM	20	4	15.00
11:30 AM	20	4	15.00

This yield test report is for informational purposes only. Please note the yield may increase or decrease over time and the GPM indicated above is not a guarantee.