



Kelly Plumbing Services, Inc  
P.O. Box 280  
Phoenix, MD 21131  
410-771-0019  
Kellyplumbing84@gmail.com

[www.kellyplumbingservices.com](http://www.kellyplumbingservices.com)

MD License # 4605

May 26, 2022

TO: Ken Thompson, 3519 Stansbury Mill Road, Phoenix MD 21131


WELL YIELD TEST FOR: 3519 Stansbury Mill Road, Phoenix MD 21131


DATE OF TEST: May 26, 2022

Well yield test was started at 9:45 a.m. today. Static water level and depth of well: unknown. Test hose was pulled off of an existing exterior hose bib. No well tag was visible and there was no information at Baltimore County on this particular well.

TIME OF TEST READINGS	G.P.M.
9:45 a.m.	7.5
10:00 a.m.	6
10:15 a.m.	6
10:30 a.m.	6
10:45 a.m.	6
11:00 a.m.	6
11:15 a.m.	6
11:30 a.m.	6
11:45 a.m.	6
12:00 p.m.	5.5
12:15 p.m.	5.5
12:30 p.m.	5.5
12:45 p.m.	5.5
1:00 p.m.	5.5
1:15 p.m.	5.5
1:30 p.m.	5.5

Test times were observed by Kelly Plumbing Services.

  
Robert T. Kelly, Pres.

  
Date

RTK:co