



9/25/20

AJ Billig
6500 Falls Rd
Baltimore Md
21209

Below test results are for the property 4148 U Way Havre de Grace Md, 21078

11:15. 7 gallon per minute
11:25. 7 gallon per minute
11:35. 7 gallon per minute
11:44 Well pumped off, no water
11:54 allowed to rest 10 min
Produced 5 gallon total
12:04. Allowed to rest 10 min
Produced 5 gallon total
12:14. Allowed to rest 10 min
Produced 5 gallon total
12:34. Allowed to rest 20 min
Produced 10 gallon total
12:44. Allowed to rest 10 min
Produced 5 gallon total

Conclusion:

The water well at 4148 U Way in Havre de Grace Md has a production rate of .5 gallons per minute. Approximate total volume of water column in well is 133 gallons.

Water test:

Raw Sample - Ph 7.4, Hardness 12 gpg, Iron 2.3 ppm
Treated Sample - Ph 7.4, Hardness 4 gpg, Iron .5 ppm

Bacteria and Nitrates Test to Follow

Chris Umbarger
717-479-5331
Svc Mgr
Culligan Mid Atlantic
8290 Miller park Dr
New Freedom Pa, 17331