



AJ Billig Company
6500 Falls Rd
Baltimore Md
21209
shannon@ajbillig.com

Below report is well yield and water testing results that were completed on 10/10/2022 at **17700 Foreston Rd Upperco Md 21155.**

- **Well yielded an Avg of 13.5 GPM Over 3 Hours**
- **Hardness - 4 GPG**
- **PH - 5.5**
- **Iron - 1.0 PPM**
- **Total Dissolved Solids - 70**
- **Significant Sediment coming from well**
- **Currently there is a 2.5"x10" Sediment filter in place, Post PT Tank**
- **Property Failed for Bacteria**

Please call contact information below, should there be any questions.

Chris Umbarger
Svc Manager
8290 Miller Park Dr
New Freedom Pa
17349
umbarger@culliganma.com
717-818-5119