

AJ Billig Company
Luis Arrazola
6500 Falls Rd
Baltimore Md
21209

3/19/24

See below for well yield and testing report for 1422 Weisburg Rd in White Hall Md 21161

Well Yield Test:

- **14.18 Gallon Per Min Over 180 Minutes**

General Testing:

- **Hardness – 6 Grains Per Gallon**
- **PH – 6.0**
- **Iron – 5.5 Parts Per Million**

Summary:

- **Over The course of testing, Tester noted heavy Sediment and Sulphur smell. Noted that well yield was very good and at no point did well production fall off or need to shut down for recovery during testing.**

Chris Umbarger
Service Manager
717-479-5331