

AJ Billig Company
Dan Billig
6500 Falls Rd
Baltimore Md
21209

5/10/24

See below for well yield and testing report for 4815 Sweet Air Rd. Baldwin Md,
21013

Well Yield Test:

- **5.5 Gallons Per Min Over 180 Minutes**

General Testing:

- **Arsenic - 0 ug/L Pass, threshold 10.00 per EPA Limits**
- **Lead - 0 ug/L Pass, threshold 15.00 per EPA Limits**
- **Nitrates - .47 mg/L Pass, threshold 10.00 per EPA Limits**
- **Nitrites - 0 mg/L Pass, threshold 1.00 per EPA Limits**
- **E. Coli - Negative**
- **Total Coliform - Negative**

Chris Umbarger
Service Manager
Culligan Mid Atlantic
717-479-5331